



BROWARD SHERIFF'S OFFICE
DEPARTMENT OF FIRE RESCUE
AND EMERGENCY SERVICES



UNSAFE STORAGE/STRUCTURE
2970-2990 NW 27 St. Lauderdale Lakes

SA 15-01

**SAFETY
WARNING**

CAD ZONE: 37

DISTRICT(S) Lauderdale Lakes

DATE: 6/30/15

NOTIFICATION OF HAZARDOUS CONDITION

This property is a 10,250 square ft. non-sprinkled carpet recycling center. They store and bale carpet and carpet padding to ship out. Currently, amongst the storage, there is approximately 5,000 square ft. that is almost 20 ft in height, solid piled, with no access to some areas for hose streams. Each bale is approximately 1,000 lbs.

This commodity is primarily polyurethane, polypropylene, and PET plastic, all Group A plastics that burn with a very high heat release rate. The roof has light gauge steel trusses with no fire protection. Several of the overhead doors are blocked with storage, and access will not be possible through them without heavy equipment movers.

This occupancy usually operates during business hours with 4-5 employees. The only hazardous materials stored routinely is LP for a forklift, with spare cylinders kept outdoors on the south side of the structure.

We are working with the owner to get the violations corrected. Until such time use caution with any response to this location.



Division of EMS
2601 West Broward Boulevard
Fort Lauderdale, FL 33312

Phone :: 954-831-8254

Fax :: 954-831-8265

Email :: tammy_nugent@sheriff.org